



NOTES:

1. RESTRAIN ALL JOINTS ON 6" BLOWOFF PIPING, SEE SPECIFICATIONS
2. SET VALVE BOX AND MANHOLE RIM TO FINISHED GRADE OR AS SHOWN ON THE DRAWINGS.
3. MANHOLE SHALL BE LOCATED AS SHOWN UNLESS OTHERWISE INDICATED ON THE DRAWINGS.
4. SEE DETAIL W/2.8 FOR V-BIO POLYETHYLENE ENCASMENT AT MANHOLE INTERFACE.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21

Mike Hermann
Chief Engineer

STANDARD DETAIL
TYPE "A" BLOWOFF
FOR WATER MAINS
36-INCH AND LARGER

W
3.02