



NOTES:

1. TEST LEADS SHALL BE STRANDED COPPER WIRE WITH TW, THW OR THWN.
2. AFTER INSTALLATION AND ASSEMBLY, TEST INSULATING JOINT
3. FOR COATING OF INSULATING JOINT, SEE DETAIL C/3.0a.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
M. H. Harmon
Chief Engineer

STANDARD DETAIL
INSULATED FLANGE
JOINT DETAIL

C
3.0