



PLAN

ELEVATION

	NOMINAL DIAMETER OF PLUG OR CAP						
	4"	6"	8"	10"	12"	14"	16"
L	2'-0"	3'-0"	4'-0"	6'-0"	7'-0"	8'-0"	9'-0"
H	1'-6"	2'-0"	3'-0"	3'-0"	3'-6"	4'-0"	4'-6"
T	1'-0"	1'-0"	1'-6"	2'-6"	3'-0"	3'-6"	4'-0"
F	1'-0"	1'-0"	1'-0"	1'-0"	1'-6"	1'-6"	2'-0"

NOTE:

1. SEE BLOCKING DESIGN REQUIREMENT NOTES, DETAIL B/1.0.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
M. Hammur
Chief Engineer

STANDARD DETAIL
THRUST BLOCKS FOR
PLUGS AND CAPS

B
1.4