



NOTES:

1. SEE DETAIL B/3.1b FOR THRUST BLOCK AND HARNESSSED JOINT DETAIL.
2. SEE DETAIL C/3.0 FOR INSULATING JOINT DETAILS.
3. FOR ANODE AND TEST LEAD WIRES, SEE DETAILS C/3.3 OR C/3.4 AS APPROPRIATE.
4. ALL NUTS AND BOLTS SHALL BE TORQUED IN ACCORDANCE WITH SPECIFICATIONS.
5. AFTER INSTALLATION AND ASSEMBLY, TEST INSULATING JOINT TO VERIFY ISOLATION OF JOINT.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
Mike Hammer
Chief Engineer

STANDARD DETAIL
INSULATED TIE RODS
ON INSULATED
FLANGE JOINT

C
3.6