



NOTES:

1. WHEN THE TEST STATION IS NOT DIRECTLY OVER THE PIPELINE, USE DETECTABLE WARNING TAPE 12" ABOVE THE LEAD WIRES.
2. LOCATE TEST STATION OUTSIDE OF PROPOSED OR EXISTING PAVED AREAS OR SIDEWALKS. (2' BACK IF POSSIBLE).
3. SEE DETAIL C/4.0a FOR WIRE TERMINATIONS.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
Mike Harmon
Chief Engineer

STANDARD DETAIL
FLUSH - MOUNTED
TEST STATION

C
4.0