



NOTES:

1. EXCEPT AS NOTED ABOVE, TEST LEAD WIRES SHALL MEET THE REQUIREMENTS OF DETAIL C/3.0
2. RUN ALL WIRES IN 2" PVC SHC. 40 CONDUIT FROM THE CONNECTION POINT UNTIL THEY REACH THE BOTTOM OF THE TEST STATION ASSEMBLY.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21

Mike Harmon

Chief Engineer

STANDARD DETAIL

TEST STATION
WITH REFERENCE CELL

C
4.5