



**NOTES:**

1. ANODES PLACED AT SAME DEPTH AS THE BOTTOM OF PIPE AND AT A MINIMUM OF 12" FROM EDGE OF PIPE.
2. DO NOT THERMITE WELD TO PVC PIPE.
3. SEE SPECIFICATION FOR ANODE SIZE.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 7-26-21  
*Mohi Aarman*  
Chief Engineer

STANDARD DETAIL  
PVC AWWA C-900 PIPE  
TAPPING SLEEVE AND VALVE

C  
7.2