



**NOTES:**

1. SEE DETAIL C/1.0 FOR BOND WIRE SIZE AND INSULATION.
2. DO NOT INSTALL BOND WIRES BETWEEN NEW AND EXISTING PIPE

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 7-26-21  
*M. W. Harman*  
Chief Engineer

STANDARD DETAIL  
BONDING OF EXISTING PIPE WITH  
CATHODIC PROTECTION WHEN  
CONNECTING TO NEW  
METALLIC WATER MAINS

C  
1.2a