



NOTES:

1. ANODES PLACED AT SAME DEPTH AS THE BOTTOM OF PIPE AND AT A MINIMUM OF 12" FROM EDGE OF PIPE.
2. DO NOT THERMITE WELD TO PVC PIPE.
3. SEE SPECIFICATION FOR ANODE SIZE.
4. IF COUPLING IS EPOXY COATED, REMOVE FROM COUPLING RING WHERE BOLTS ARE MOVED

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
M. Hammer
Chief Engineer

STANDARD DETAIL
PVC AWWA C-900 PIPE
ANODE PROTECTION COUPLING

C
7.7