



NOTES:

1. ANODES PLACED AT SAME DEPTH AS THE BOTTOM OF PIPE AND AT A MINIMUM OF 12" FROM EDGE OF PIPE, SEE DETAIL C/7.13.
2. DO NOT THERMITE WELD TO PVC PIPE.
3. BOND ALL JOINTS ON DIP, SEE DETAILS C/1.0 AND C/1.1.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21

Milo Harman
Chief Engineer

STANDARD DETAIL
PVC AWWA C-900 PIPE
4-INCH TO 12-INCH
ANODE PROTECTION FOR
WATER HOUSE CONNECTION

C
7.9