

- 1. METER SETTING FOR NON-TRAFFIC AREAS ONLY, DO NOT LOCATE IN SIDEWALK OR DRIVEWAY, UNLESS OTHERWISE NOTED ON THE DRAWINGS.
- 2. COMPACT BACKFILL AND AGGREGATE BASE AS STRUCTURAL FILL.
- 3. 2" SINGLE METER SETTER IS COMPLETE ONE—PIECE FACTORY ASSEMBLED, INCLUDING TWO ANGLE BALL VALVES, FITTINGS AND COMPRESSION CONNECTIONS.
- 4. RESTRAIN ALL PIPE JOINTS ON 4" DUCTILE IRON SERVICE, FROM THE MAINLINE WATER MAIN TO THE 4" RESTRAINED CAP OR PLUG
- 5. EXTEND COPPER SERVICE OUTLET 3'-0" MINIMUM BEYOND METER BOX OR PROPERTY LINE, WHICHEVER IS GREATER.
- 6. V-BIO REQUIRED ON NEW COPPER PIPE, SEE SPECIFICATIONS.

WASHINGTON SUBURBAN SANITARY COMMISSION APPROVED: 7-26-21

Mil Harnum

Chief Engineer

STANDARD DETAIL

2-INCH METER SETTING FOR EXISTING 2-INCH METER REPLACEMENT W 5.9a