



PLAN VIEW
NO SCALE

NOTES:

1. SEE DETAIL C/1.0 FOR BOND WIRE SIZE AND INSULATION.
2. PROVIDE SLACK IN WIRES AND FASTEN TO VAULT TO PROTECT WIRES FROM DAMAGE.

WASHINGTON
SUBURBAN
SANITARY
COMMISSION

APPROVED: 7-26-21
Mike Harmon
Chief Engineer

STANDARD DETAIL
DUCTILE IRON PIPE
BONDING AROUND
VALVE VAULT

C
1.3