



PIPE SIZE	M	N	P
1 1/4"	6"	6"	8"
1 1/2"	6"	6"	8"
2"	6"	8"	8"
2 1/2"	8"	8"	10"
3"	12"	18"	12"
4"	12"	18"	12"

**NOTES:**

1. CARRY ALL BEARING SURFACES TO UNDISTURBED EARTH OR FIRM SUBGRADE.
2. BUTTRESS SIZED FOR 150 psi.
3. NOMINAL THICKNESS OF ALL BOARDS IS 2".
4. ALL BOARDS TO BE PRESSURE TREATED YELLOW PINE.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 7-26-21

*M. H. Hansen*  
Chief Engineer

STANDARD DETAIL  
PRESSURE SEWER AND  
HOUSE CONNECTION  
BLOCKING DETAILS  
FOR CAPS AND PLUGS

PS  
1.41