



#### NOTES:

1. FOR INSIDE METER SETTINGS, TERMINATE WATER HOUSE CONNECTION WITH A MJ CAP. FOR OUTSIDE METER SETTINGS, SEE DETAILS W/5.0a, W/5.0d, W/5.1c, W/5.9, W/5.9a AND W/12.0a.
2. LAY SERVICE LEVEL UNLESS OTHERWISE NOTED ON THE DRAWINGS.
3. RESTRAIN ALL JOINTS ON WATER HOUSE CONNECTION.
4. IF BENDS ARE INSTALLED ON WATER HOUSE CONNECTION PROVIDE BLOCKING. SEE DETAILS B/1.0 AND B/1.8

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 7-26-21

*Mike Hamner*  
Chief Engineer

STANDARD DETAIL

4-INCH THRU 12-INCH  
DUCTILE IRON  
WATER HOUSE CONNECTION

W  
5.12