

| Potomac Filtration Plant |  |              |                               |                     |
|--------------------------|--|--------------|-------------------------------|---------------------|
| Sample date              | Per- and polyfluoroalkyl substances (PFAS) | Result (ppt) | Minimum Reporting Level (ppt) | EPA Health Advisory |
| March, 2021              | NEtFOSAA                                   | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | NMeFOSAA                                   | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | Perfluorobutanesulfonic acid (PFBS)        | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | Perfluorodecanoic acid (PFDA)              | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | Perfluorododecanoic acid (PFDoA)           | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | Perfluoroheptanoic acid (PFHpA)            | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | Perfluorohexanesulfonic acid (PFHxS)       | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | Perfluorohexanoic acid (PFHxA)             | 2.5          | 2.0                           | n/a <sup>1</sup>    |
|                          | Perfluorononanoic acid (PFNA)              | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | Perfluorooctanesulfonic acid (PFOS)        | 2.2          | 2.0                           | 70 ppt <sup>2</sup> |
|                          | Perfluorooctanoic acid (PFOA)              | not detected | 2.0                           | 70 ppt <sup>2</sup> |
|                          | Perfluorotetradecanoic acid (PFTeDA)       | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | Perfluorotridecanoic acid (PFTrDA)         | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | Perfluoroundecanoic acid (PFUnA)           | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | 11CI-PF3OUdS                               | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | 9CI-PF3ONS                                 | not detected | 2.0                           | n/a <sup>1</sup>    |
|                          | DONA                                       | not detected | 2.0                           | n/a <sup>1</sup>    |
| HFPODA                   | not detected                               | 2.0          | n/a <sup>1</sup>              |                     |

| Patuxent Filtration Plant |  |              |                               |                     |
|---------------------------|--|--------------|-------------------------------|---------------------|
| Sample date               | Per- and polyfluoroalkyl substances (PFAS) | Result (ppt) | Minimum Reporting Level (ppt) | EPA Health Advisory |
| March, 2021               | NEtFOSAA                                   | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | NMeFOSAA                                   | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | Perfluorobutanesulfonic acid (PFBS)        | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | Perfluorodecanoic acid (PFDA)              | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | Perfluorododecanoic acid (PFDoA)           | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | Perfluoroheptanoic acid (PFHpA)            | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | Perfluorohexanesulfonic acid (PFHxS)       | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | Perfluorohexanoic acid (PFHxA)             | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | Perfluorononanoic acid (PFNA)              | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | Perfluorooctanesulfonic acid (PFOS)        | not detected | 2.0                           | 70 ppt <sup>2</sup> |
|                           | Perfluorooctanoic acid (PFOA)              | not detected | 2.0                           | 70 ppt <sup>2</sup> |
|                           | Perfluorotetradecanoic acid (PFTeDA)       | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | Perfluorotridecanoic acid (PFTrDA)         | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | Perfluoroundecanoic acid (PFUnA)           | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | 11CI-PF3OUdS                               | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | 9CI-PF3ONS                                 | not detected | 2.0                           | n/a <sup>1</sup>    |
|                           | DONA                                       | not detected | 2.0                           | n/a <sup>1</sup>    |
| HFPODA                    | not detected                               | 2.0          | n/a <sup>1</sup>              |                     |

**Defintions**

ppt = parts per trillion. One part per trillion is equivalent to one drop of water in 20 olympic-sized swimming pools

Minimum Reporting Level : The lowest concentration at which an analyte can be detected in a sample and its concentration can be reported with a reasonable degree of accuracy and precision

Not Detected : A compound is either not present or present at such low concentrations that it cannot be accurately detected by the analytical method.

**Footnotes**

<sup>1</sup> n/a = not applicable. There are no known health standards for these compounds

<sup>2</sup> Health advisories are specifically for individual or combined PFOA and PFOS concentrations and do not apply to other PFAS compounds